

ADDENDUM #3

for

University of Missouri

Teaching Hospital

**CCA & TH EMERGENCY POWER
MODIFICATIONS – CP210961**

Issued by:



8/20/2021

ADDENDUM #3

August 20, 2021

The following list contains the Addendum #3 information:

Addendum #3 SUMMARY:

Summary list below is not meant to be all-inclusive, bidder is responsible for providing complete pricing based on the information on the drawings. This is not a change order, a construction change directive or a direction to proceed with the work described in the proposed modifications.

Drawings

- E-101: Relocated electrical equipment and added requirement to replace covers on existing panels GL-4, GL-5, and GL-6.
- E-102: Added tap to PSG1 bus and connection to separately enclosed circuit breaker for service to the fire pump.
- E-104: Modified power source for CT-1E17 to be from panel DP-RAD.
- E-106: Modified power source for CT-1E17 to be from panel DP-RAD.
- E-501: Added fused switch on the secondary side of temporary transformer X-4. Added requirement for new breakers to be TMAX type.
- E-502: Added tap to PSG1 bus and connection to separately enclosed circuit breaker for service to the fire pump. Added requirement for new breakers to be TMAX type.
- E-503: Modified power source for CT-1E17 to be from panel DP-RAD. Added requirement for new breakers to be TMAX type.
- E-701: Updated detail to include feeder for CT-1E17 from panel DP-RAD.

END OF ADDENDUM #3