

ADDENDUM #1

DATE: February 4, 2022

Page 1 of 1

TO CONTRACT DOCUMENTS ENTITLED:

PROJECT MANUAL FOR:

VARIOUS LOCATIONS- REPAIR CONCRETE IN STEAM
MANHOLES

PROJECT NUMBER: CP220041

ADVERTISEMENT DATE: January 18, 2022

PREPARED FOR: The Curators of the University of Missouri

CONSULTANT:
Crockett Engineering Consultants
1000 W. Nifong Blvd., Bldg. #1
Columbia, Missouri

Drawings and Specifications for the above noted project and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

GENERAL CLARIFICATIONS

1. The Supplier Diversity Participation Goals as shown on page 1.A-3 of the Lump Sum Bid Contract are correct as shown.

SPECIFICATION

1. No changes.

DRAWING CHANGES:

1. Sheet S202, detail 2, the width of the new riser should coincide with the size of the existing manhole lid that will be reinstalled.
2. Sheet S202, updated the note number under the second photo from the left.
3. Sheet S204, SMH #603 Notes, note #5, the contractor shall allow the owner two weeks to install the steam pipes, thus the shoulder closure will need to remain in place for this additional week.
4. Sheet S205, detail 3, updated the quantity of bent bars in the concrete pad.
5. Sheet S206, detail 2, updated the quantity of bent bars in the concrete pad.

END OF ADDENDUM #1