

March 5, 2025

ADDENDUM #01

TO CONTRACT DOCUMENTS FOR: Project #CP243181 – Various Locations - Roof Replacement

ADVERTISEMENT DATE: February 25, 2025

PREPARED FOR: The Curators of the University of Missouri

CONSULTANT: RMT Roofing & Waterproofing Consultants
Attn: Ryan O’Connell
410 Sovereign Court, Ste. 18
Manchester, MO 63011
(636) 391-2185

The contract documents for the above noted project and the work covered thereby and herein modified.

PROJECT MANUAL:

- 1) Specification Section 1.E, Paragraph 2.b: **DELETE** paragraph in its entirety and **REPLACE** with the following:
 - b. Contractor to start at Mizzou Athletic Training Complex (MATC) as priority with a construction start within ten (10) days of the start of the contract period and completion no later than June 1, 2025
- 2) Specification Section 26 4113, Lightning Protection for Structures: **CLARIFICATION:** The contractor must engage the services of a UL certified inspection agency and obtain the proper documentation to re-certify existing lightning protection system.

DRAWINGS:

- 1) Drawing Sheet A301, Renovation Plan, Detail 2/A301, Site Coordination Plan: **DELETE** the current note and **REPLACE** with the following note in its entirety:

Existing electrical equipment to remain in place. Contractor to provide protection for equipment to avoid damage. Contractor required to protect electrical equipment with metal structure, scaffolding or similar, with two layers of plywood secured to the top.

END OF ADDENDUM #01